

## 2107 HMI Loading Instructions

### To update the GT2107 HMI:

Install the new SDHC card and wait for the SDHC card not installed banner to clear (usually 10 seconds). If it doesn't remove the card and put it in again – closing the door also.

1. Go to the first Factory Authorized screen (password 6700).
2. Press the HMI Utility button in the upper right corner.
3. Press the Data Folder.
4. Press the Clear Data Folder.
5. Press the top button, Project Data. Press YES when prompted to clear the data. Now Clearing will appear. This process takes several minutes, after which the HMI will automatically reboot. Please let the process complete without interruption. When finished, a data not found window will appear. Close it.
6. Press the Data Folder again.
7. Press the Data Copy Folder.
8. Under SOURCE, press the button until it says SD Card.
9. Under DESTINATION, press the button until it says GOT.
10. Press OK.
11. The HMI should display the direction of the data copy as SD Card -> GOT. If it does, Press OK.
12. Press Yes when asked to continue copy.
13. The process takes several minutes. Please let it complete without doing anything else. Once done, it will reboot the HMI and it will be updated.